

Proportioning for Mass Concrete


Darrell F. Elliot, FACI
Technical Service Manager
Buzzi Unicem USA

What is Mass Concrete?

ACI defines Mass Concrete as “any volume of concrete with dimensions large enough to require that measures be taken to cope with generation of heat from hydration of the cement and attendant volume change to minimize cracking.”

ACI does not specify an exact minimum thickness, depends on many factors

Hoover Dam - 660 ft (200 m) wide base



Traditional Mass Concrete Mixes

**Low strength requirements
56 or 90 days to achieve
strength**

Very large coarse aggregate

Very low cement contents


Type IV or Type II(MH)

High SCM replacements

Mat Foundations, Houston

| | Volume | PSI |
|-------------------------|---------------|--------------|
| ENRON Building | 11,000 | 5,000 |
| 5 Houston Center | 8,500 | 6,000 |
| 1000 Main | 12,000 | |
| M D Anderson (2) | 12,000 | |





Mass Concrete

For mass placements, ACI 207 and U. S. Army Corps of Engineers recommend:

Cement or combination of cement with GGBFS and/or fly ash that achieves a maximum Heat of Hydration of 70 cal/gm at 7 days.





Critical Temperature Limits

$$T_{\max} < 165^{\circ}\text{F} \text{ (} 75^{\circ}\text{C)}$$

$$\Delta T < 35^{\circ}\text{F} \text{ (} 20^{\circ}\text{C)}$$

Why these Limits?

$$T_{\max} < 165^{\circ}\text{F} \text{ (} 75^{\circ}\text{C)}$$

Potential to bypass ettringite phase, resulting in DEF

$$\Delta T < 35^{\circ}\text{F} \text{ (} 20^{\circ}\text{C)}$$

Thermal Stress of different expansion & contraction

Heating and Cooling

Initial heat generated


**The quicker the peak,
the higher the peak
(less cooling time)**

- **As outside cools, inside remains hot.**
- **As inside cools, it contracts & pulls away from perimeter, cracks**


**Early Condition:
Large Heat Generation,
Little Time for Cooling**

**Later Condition:
Cooling from the Outside**

Time-Temperature Plot



Cracking in Top of Pile Cap



Heat Energy

Calculating the change in temperature in a system may be accomplished by using the following formula:

$$\text{Change in Temperature} = \frac{\text{Heat gained or lost}}{\text{Mass} \times \text{Specific Heat}}$$

Specific heat is defined as the amount of heat energy required to raise 1 g of a substance by 1° Celsius.

GGBF slag
grade 120



Si Silica Fume
(microsilica)



Portland Cement
Type 1



Fly Ash
class C

Types Of Portland Cement ASTM C150

I Normal

II Moderate Sulfate Resistance


**Optional Moderate Heat
(MH)**

III High Early Strength

IV Low Heat of Hydration

V High Sulfate Resistance

Fly Ash Reduces Heat



Fly Ash Reduces Heat

“The temperature rise can be reduced by using fly ash as a portion of the cementitious material in concrete.”

Class F fly ashes almost always reduce heat.

However, be aware that some Class C fly ash may reduce heat, some are heat neutral, and some actually increase heat.

Slag Cement Reduces Heat




Fig. 1.4—Rate of heat liberation of cements with and without GGBF slag at 27 C (80 F) (Roy and Idorn 1982)

Slag Cement Advantages

**Lower Heat of Hydration,
fewer calories/gram of
cement**

**Higher strength performance,
fewer grams of cement,
hence less total heat generated**

U S Army Corps of Engineers


Mass Concrete Application

Davis Pond Diversion Project

Luling, LA

1999

Heat of Hydration with Type II



ASTM & U S Army Corps of Engineers limit heat to 70 calories/gram at 7 days.



**LAMBERT ST. LOUIS
INTERNATIONAL
AIRPORT**
ST. LOUIS, MISSOURI

WELCOME
WILLKOMMEN
BIENVENUE
BIENVENIDO

ようこそ！
セントルイスへ
歓迎







OTHER SIDE

CON-CURE II

Model No. 2000
List No. 2000
CON-CURE COM
1313 18th Street Dr.
Tomball, TX 77375 USA

POUR AGAIN



Insulating Values, R

Extruded Polystyrene **5.00/inch**

2 inches x 5.00 per inch = 10.00

Normal Weight Concrete **0.11/inch**

R-10 / R-0.11 per inch = 91 inches

**4" Polystyrene is equivalent to 7'7" of
Concrete**







| Mix Description | Aggregate | 1 Day Average | 2 Day Average | 7 Day Average | 14 Day Average | 28 Day Average |
|-----------------|--------------|---------------|---------------|---------------|----------------|----------------|
| 545 Mass-4 | 57 Limestone | 2359 | 3657 | 4983 | 5314 | 5454 |
| 545 Mass-1A | 57 Limestone | 1302 | 2638 | 3734 | 3905 | 4475* |
| 545 Mass-2 | 57 Limestone | 1828 | 3477 | 4476 | 4958 | 5145 |
| 500 Mass-1B | 467 Gravel | 1143 | 2665 | 4104 | 4643 | 4824 |
| 545 Mass-1B | 467 Gravel | 1716 | 3334 | 4906 | 5088 | 5398 |
| 590 Mass-1B | 467 Gravel | 1451 | 2904 | 4332 | 4857 | 4846 |
| 500 Mass-3 | 57 Gravel | 1699 | 3152 | 4490 | 4838 | 5351 |
| 545 Mass-3 | 57 Gravel | 1591 | 2933 | 4201 | 4608 | 5173 |
| 590 Mass-3 | 57 Gravel | 1543 | 3026 | 4464 | 4913 | 5389 |

| Mix Description | Aggregate | Ambient Temp | Mix Temp | Center Max T | Face Max T |
|------------------------|---------------------|---------------------|-----------------|---------------------|-------------------|
| 545 Mass-4 | 57 Limestone | 85 | 76 | | |
| 545 Mass-1A | 57 Limestone | 85 | 76 | 144 | 139 |
| 545 Mass-2 | 57 Limestone | 95 | 77 | | |
| 500 Mass-1B | 467 Gravel | 85 | 76 | 133 | 132 |
| 545 Mass-1B | 467 Gravel | 90 | 78 | 137 | 135 |
| 590 Mass-1B | 467 Gravel | 90 | 78 | 141 | 133 |
| 500 Mass-3 | 57 Gravel | 95 | 82 | 140 | 137 |
| 545 Mass-3 | 57 Gravel | 95 | 79 | 135 | 135 |

Dynergy Power Plant

Cayuga, IN

Maximum In-Place Concrete Temperature Estimator

Portland Type I & Grade 100 Slag

Thickness

10

Feet

Length

295

Feet

Width

133

Feet

Volume

14,531

Yards³

| | | |
|------------------|---------------|--------------------------|
| Thickness | 10 | Feet |
| Length | 295 | Feet |
| Width | 133 | Feet |
| Volume | 14,531 | Yards³ |

| | | | | |
|--------------|--------------|--------------|--------------|------------------|
| #1 | #2 | #3 | #4 | |
| 85 | 80 | 75 | 70 | °F |
| 216 | 216 | 216 | 216 | Lb/Cu.Yd. |
| 324 | 324 | 324 | 324 | Lb/Cu.Yd. |
| 3933 | 3933 | 3933 | 3933 | Lb/Cu.Yd. |
| 60 | 60 | 60 | 60 | Cal/gm |
| 60 | 60 | 60 | 60 | Cal/gm |
| #1 | #2 | #3 | #4 | |
| 61.71 | 61.71 | 61.71 | 61.71 | °F |
| 85.0 | 80.0 | 75.0 | 70.0 | °F |
| 146.7 | 141.7 | 136.7 | 131.7 | °F |



**Patriot Engineering
Cayuga FGD Project
Middle Section: Absorber Building**


| | |
|---|-----------------------|
| Logger | |
| S/N: | 4048284 |
| Job: | CAYUGA FGD |
| Location: | NE CORE ABSORBR |
| Logger ID: | TPL-02-1H28D |
| Run State: | Locked |
| Start Date: | 9/27/2005 10:30:34 AM |
| Elapsed Date (Start Date + Elapsed Time): | 10/18/2005 1:59:34 PM |
| Elapsed Time (hrs): | 507.48 |
| Data Interval (min): | 60 |
| Number of readings: | 508 |

Events

| Time (hrs) | Event Description | Temperature (°F) |
|------------|-------------------|------------------|
| 0.00 | MIN TEMPERATURE | 107.5 |
| 49.37 | MAX TEMPERATURE | 134.6 |
| 507.48 | LAST READING | 107.5 |

**Patriot Engineering
Cayuga FGD Project
Middle Section: Absorber Building**

CAYUGA FGD at N CTR TOP
S/N 4048297
9/27/2005 4:38 PM to 10/18/2005 1:38 PM
20.9 Days Elapsed





LA Hwy 1 Bridge at Fourchon

Maximum In-Place Concrete Temperature Estimator

4000 psi

**50% Type I/II Portland, 50% G120 Slag
+ 5% Silica Fume**

Thickness

8

Feet

Length

67

Feet

Width

47

Feet


Volume

933

Yards³

| | | #1 | #2 | #3 | #4 | Inch-Pound |
|------------|-------------------------|-------|-------|-------|-------|------------|
| T_i | Initial Concrete Temp. | 40 | 60 | 80 | 90 | °F |
| P | Mass of Portland Cement | 300 | 300 | 300 | 300 | Lb/Cu.Yd. |
| S | Mass of Slag Cement | 300 | 300 | 300 | 300 | Lb/Cu.Yd. |
| F | Mass of Silica Fume | 30 | 30 | 30 | 30 | Lb/Cu.Yd. |
| W | Unit Weight of Concrete | 3907 | 3907 | 3907 | 3907 | Lb/Cu.Yd. |
| H_1 | Heat of Hydration - PC | 61.5 | 61.5 | 61.5 | 61.5 | Cal/G |
| H_2 | Heat of Hydration - SC | 61.5 | 61.5 | 61.5 | 61.5 | Cal/G |
| H_3 | Heat of Hydration - SF | 61.5 | 61.5 | 61.5 | 61.5 | Cal/G |
| | | | | | | |
| T_i | Initial Temperature | 40.0 | 60.0 | 80.0 | 90.0 | °F |
| ΔT | Temperature Gain | 74.3 | 74.3 | 74.3 | 74.3 | °F |
| T_{max} | Maximum Temperature | 114.3 | 134.3 | 154.3 | 164.3 | °F |

Pier 1 Footing - Temperature Monitoring




Sempra – Cameron LNG Compressor Foundations

| Cement Plant | C | F |
|----------------------------|-------------|----------|
| Type I/II | 80.6 | |
| 80.7 | | |
| 50% Slag, 25% F Ash | 50.8 | |
| 58.2 | | |


Sempre – Cameron LNG

| | | Scenario | Scenario | Scenario | Scenario | Inch-Pound |
|------------|---------------------------------------|----------|----------|----------|----------|------------|
| | | #1 | #2 | #3 | #4 | Units |
| T_i | Initial Concrete Temp. | 70 | 75 | 80 | 85 | °F |
| P | Mass of Portland Cement | 132 | 132 | 132 | 132 | Lb/Cu.Yd. |
| S | Mass of Slag Cement | 265 | 265 | 265 | 265 | Lb/Cu.Yd. |
| F | Mass of Fly Ash | 133 | 133 | 133 | 133 | Lb/Cu.Yd. |
| W | Mass of 1 yd ³ of Concrete | 3877 | 3877 | 3877 | 3877 | Lb/Cu.Yd. |
| H_1 | Heat of Hydration, Portland | 58.2 | 58.2 | 58.2 | 58.2 | Cal/G |
| H_2 | Heat of Hydration, Slag | 58.2 | 58.2 | 58.2 | 58.2 | Cal/G |
| H_3 | Heat of Hydration, Fly Ash | 58.2 | 58.2 | 58.2 | 58.2 | Cal/G |
| T_i | Initial Temperature | 70.0 | 75.0 | 80.0 | 85.0 | °F |
| ΔT | Temperature Gain | 59.60 | 59.60 | 59.60 | 59.60 | °F |
| T_{max} | Maximum Temperature | 129.6 | 134.6 | 139.6 | 144.6 | °F |

Sempre – Cameron LNG



Sempra – Cameron LNG



Sempre – Cameron LNG

The combined chemical composition of the total cementitious system of 25% Type I/II Portland Cement, 50% Grade 120 Slag Cement, and 25% Class F Fly Ash **ratio of SO_3 to Al_2O_3 is 0.118**. This is far below the threshold of potential for **Delayed Ettringite Formation (DEF)**. DEF typically occurs in mixes that reach temperatures in excess of 165°F and have SO_3 to Al_2O_3 **ratios in excess of 0.45 to 0.70**. This is the reason for limiting maximum temperatures in place to 165°F.

NCRA Refinery

| Cement Plant | C | P |
|---------------------|-------------|----------|
| Type I/II | 77.5 | |
| 67.8 | | |
| 25% C Ash S | 79.5 | |
| 64.5 | | |
| 25% C Ash A | 83.1 | |

NCRA Refinery

100% Type I/II **82.0**


25% Slag **70.0**


37.5% Slag **69.4**

50% Slag **64.4**

30% Slag, 20% C Ash S **67.9**

NCRA Refinery





High Strength Concrete



Manhattan / BEERS

Reliant Stadium

Houston NFL Stadium

4 Super Columns

12'6" x 25'-75' x 150'

Supporting 7,000,000 pounds

Design Strength: 13,000 psi









12.5.2000

Houston NFL Stadium

Strength of 2-Way 50/50 & 3-Way 50/30/20 Mixes





Missouri DOT
Mass Concrete Application

Page Avenue Bridge

Creve Couer Lake

St. Louis, MO

Foundation: 72' long x 35' wide x 13' deep

Reinforced with #14 bars 5" on center

Required low heat of hydration to prevent thermal stress

Limited heat of hydration to 60 cal/gram






No Type IV low-heat cement was available

Tested Type II and Type II(Moderate-Heat)

With Slag Cement at various %


Heat of Hydration

With Cape Type I/II



ASTM & U S Army Corps of Engineers limit heat to 70 calories/gram at 7 days.

Heat of Hydration with Cape Type II(MH)




ASTM & U S Army Corps of Engineers limit heat to 70 calories/gram at 7 days.



Maximum Temperature in Place

125°F



Mat Foundations, Houston

| | |
|-------------------------|---------------|
| ENRON Building | 11,000 |
| 5 Houston Center | 8,500 |
| 1000 Main | 12,000 |
| M D Anderson (2) | 12,000 |

Calories/Gram

| <u>Mixture</u> | <u>7-Day</u> | <u>28-</u> |
|----------------------------------|--------------|------------|
| <u>Day</u> | | |
| 100% Type I/II | 75.70 | |
| 87.47 | | |
| 70% T I/II + 30% Class C Fly Ash | 77.73 | |
| 89.67 | | |
| 70% T I/II + 30% Class F Fly Ash | 75.32 | |
| 71.38 | | |
| 50% Type I/II + 30% Slag | 70.17 | |
| 87.47 | | |

ENRON Building

Houston, TX

11,000 Cubic Yard

Mat Foundation

5,000 psi with Low Heat

550 # Total Cementitious

50% Portland

30% Slag

20% Fly Ash

MR W/R

5 Houston Center

Houston, TX

8,500 cubic yard

Mat Foundation

6,000 psi with Low Heat

517 # Total Cementitious

50% Portland

30% Slag

20% Fly Ash

MR W/R

Specification:

6,000 psi @ 56 Days

Performance:

6,000 + psi @ 14 Days

Max Temp - 130°F

City of Austin

Austin, TX

**45' tall x 50' wide x 3'
thick**

Chilling Towers

4,000 psi with Low Heat

517 # Total Cementitious

30% Portland

35% Slag

35% Fly Ash

MR W/R

Specification:

4,000 psi @ 28 Days

Performance:

5,500 + psi @ 28 Days

Specification:

$T < 165^{\circ}\text{F}$, $\Delta T < 35^{\circ}\text{F}$

Performance:

$T < 139^{\circ}\text{F}$, $\Delta T < 25^{\circ}\text{F}$

with Ambient = 112°F

