

An ACI Standard

# Load Testing of Concrete Structures—Code and Commentary

Reported by ACI Committee 437

ACI CODE-437.2-22



American Concrete Institute  
*Always advancing*



## Load Testing of Concrete Structures—Code and Commentary

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

Order information: ACI documents are available in print, by download, through electronic subscription, or reprint, and may be obtained by contacting ACI.

ACI codes, specifications, and practices are made available in the ACI Collection of Concrete Codes, Specifications, and Practices. The online subscription to the ACI Collection is always updated, and includes current and historical versions of ACI's codes and specifications (in both inch-pound and SI units) plus new titles as they are published. The ACI Collection is also available as an eight-volume set of books and a USB drive.

**American Concrete Institute**  
**38800 Country Club Drive**  
**Farmington Hills, MI 48331**  
**Phone: +1.248.848.3700**  
**Fax: +1.248.848.3701**

[www.concrete.org](http://www.concrete.org)

# Load Testing of Concrete Structures—Code and Commentary

An ACI Standard

Reported by ACI Committee 437

Paul H. Ziehl, Chair

Aaron K. Larosche, Secretary

Diego S. Arabbo  
Nicholas J. Carino  
Paolo Casadei  
John A. Frauenhoffer  
Nestore Galati

Zareh B. Gregorian  
Pawan R. Gupta  
Frederick D. Heidbrink  
Jason S. Johnson  
Ashok M. Kakade

Danielle D. Kleinhans  
Andrew T. Krauklis  
Daniel J. McCarthy  
Faizul M. Mohee  
Thomas E. Nehil

K. Nam Shiu  
J. Gustavo Tumialan  
Jeffery S. West

## Consulting Members

Marco Arduini  
JoAnn P. Browning  
Grant T. Halvorsen

Carl J. Larosche  
Habib M. Zien Alabideen

Note: Special acknowledgment to M. ElBatanouny for his contribution to this Code.

*This Code provides requirements for test load magnitudes, test protocols, and acceptance criteria for conducting a load test as a means of evaluating the safety and serviceability of concrete structural members and systems of structures. A load test may be conducted as part of a structural evaluation to determine whether a structure requires repair and rehabilitation, or to verify the adequacy of repair and rehabilitation measures.*

**Keywords:** acceptance criteria; cyclic loading; load test; monotonic loading; test load magnitude; test protocol.

## CONTENTS

### CHAPTER 1—GENERAL, p. 3

- 1.1—Scope, p. 3
- 1.2—General, p. 3
- 1.3—Purpose, p. 4
- 1.4—Applicability, p. 4
- 1.5—Interpretation, p. 5

### CHAPTER 2—NOTATION AND TERMINOLOGY, p. 6

- 2.1—Notation, p. 6
- 2.2—Terminology, p. 7

### CHAPTER 3—TEST LOAD, p. 9

- 3.1—Service loads, p. 9
- 3.2—Test load magnitude, p. 9

ACI CODE-437.2-22 supersedes ACI 437.2-13, was adopted by the ACI Standards Board for publication December 11, 2022, and was published March 2023.

Copyright © 2023, American Concrete Institute.

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

**CODE**

**COMMENTARY**

**CHAPTER 4—LOAD TEST PROTOCOL, p. 11**

- 4.1—Selection of test protocol, p. 11
- 4.2—Safety, p. 11
- 4.3—Load arrangement, p. 11
- 4.4—Response measurements, p. 12
- 4.5—Visual inspection, p. 12
- 4.6—Load application, p. 13
- 4.7—Monotonic load test protocol, p. 13
- 4.8—Cyclic load test protocol, p. 14

**CHAPTER 5—ACCEPTANCE CRITERIA, p. 16**

- 5.1—Distress caused by load test, p. 16

- 5.2—Performance assessment at service load level, p. 17
- 5.3—Acceptance criteria for monotonic load test protocol, p. 18
- 5.4—Acceptance criteria for cyclic load test protocol, p. 18
- 5.5—Provision for lower load rating, p. 21

**CHAPTER 6—COMMENTARY REFERENCES, p. 22**

- Authored documents, p. 22



## CODE

## CHAPTER 1—GENERAL

**1.1—Scope**

**1.1.1** The scope, purpose, applicability, limitations, interpretation principles, and units of measure are defined in this chapter.

**1.2—General**

**1.2.1** The requirements of this Code shall govern for the evaluation of safety and serviceability of members in concrete structures by load testing.

**1.2.2** The requirements of this Code shall apply to reinforced concrete structures, or portions of reinforced structures, with prestressed reinforcement, nonprestressed reinforcement, or both.

**1.2.3** Procedures and requirements provided in this Code are not applicable to structures having concretes with compressive strengths above 8000 psi unless permitted by the licensed design professional.

## COMMENTARY

## CHAPTER R1—GENERAL

**R1.1—Scope**

**R1.1.1** A load test is required if the effect of a strength deficiency is not well understood, or it is not practicable to measure the dimensions and determine the material properties of the members required for analysis.

**R1.2—General**

**R1.2.1** The determination of situations where a load test is required is outside the scope of this Code. Furthermore, this Code does not address procedures for analytical strength evaluations, condition evaluation of structures, or assessment of structural deterioration and its consequences. The licensed design professional should advise the owner and parties participating in the load testing of a structure of the potential for damage or even failure of the portions of the structure to be load tested in accordance with the procedures of this Code.

This Code may be used to evaluate whether a structure or a portion of a structure satisfies safety requirements. A strength evaluation may be required if the materials are considered deficient in quality, if there is evidence of faulty construction, if a structure will be used for a new function, or if, for any reason, a structure or a portion of it does not appear to satisfy safety requirements. In such cases, this Code provides minimum requirements for performing a strength evaluation of the structure by load testing.

If a load test is prescribed as part of the strength evaluation process, all parties should agree on the region to be loaded, the magnitude of the load, the load test protocol, and the applicable acceptance criteria before conducting the load test. If the safety concerns are related to an assemblage of members or an entire structure, it may not be feasible to load test every member and section. In such cases, an investigation plan should be developed to address the specific safety concerns.

**R1.2.2** If there is doubt or concern about the shear strength of a member or members, or the development of reinforcement, a load test may be the most efficient solution to confirm the safety of the member or structure.

A load test may also be appropriate if it is not feasible to determine the material properties and structural dimensions required for analysis, even if the cause of the concern relates to flexure or axial load.

**R1.2.3** Experience is lacking in the application of the procedures and requirements in this Code to structures having high-strength concrete—that is, compressive strengths over 8000 psi as defined in **ACI 363R**. Structures or members constructed of high-strength concrete may exhibit a response that is nearly linear as the structure approaches its load-carrying limit and, therefore, may provide little warning of an impending failure. Structures or members constructed of high-strength concrete may also experience a more brittle