

An ACI Standard

Specifications for Repair of Concrete in Buildings (ACI 563-18)

Reported by ACI Committee 563

ACI 563-18



American Concrete Institute
Always advancing



Specifications for Repair of Concrete in Buildings (ACI 563-18)

Copyright by the American Concrete Institute, Farmington Hills, MI. All rights reserved. This material may not be reproduced or copied, in whole or part, in any printed, mechanical, electronic, film, or other distribution and storage media, without the written consent of ACI.

The technical committees responsible for ACI committee reports and standards strive to avoid ambiguities, omissions, and errors in these documents. In spite of these efforts, the users of ACI documents occasionally find information or requirements that may be subject to more than one interpretation or may be incomplete or incorrect. Users who have suggestions for the improvement of ACI documents are requested to contact ACI via the errata website at <http://concrete.org/Publications/DocumentErrata.aspx>. Proper use of this document includes periodically checking for errata for the most up-to-date revisions.

ACI committee documents are intended for the use of individuals who are competent to evaluate the significance and limitations of its content and recommendations and who will accept responsibility for the application of the material it contains. Individuals who use this publication in any way assume all risk and accept total responsibility for the application and use of this information.

All information in this publication is provided “as is” without warranty of any kind, either express or implied, including but not limited to, the implied warranties of merchantability, fitness for a particular purpose or non-infringement.

ACI and its members disclaim liability for damages of any kind, including any special, indirect, incidental, or consequential damages, including without limitation, lost revenues or lost profits, which may result from the use of this publication.

It is the responsibility of the user of this document to establish health and safety practices appropriate to the specific circumstances involved with its use. ACI does not make any representations with regard to health and safety issues and the use of this document. The user must determine the applicability of all regulatory limitations before applying the document and must comply with all applicable laws and regulations, including but not limited to, United States Occupational Safety and Health Administration (OSHA) health and safety standards.

Participation by governmental representatives in the work of the American Concrete Institute and in the development of Institute standards does not constitute governmental endorsement of ACI or the standards that it develops.

Order information: ACI documents are available in print, by download, through electronic subscription, or reprint and may be obtained by contacting ACI.

Most ACI standards and committee reports are gathered together in the annually revised the ACI Collection of Concrete Codes, Specifications, and Practices.

American Concrete Institute
38800 Country Club Drive
Farmington Hills, MI 48331
Phone: +1.248.848.3700
Fax: +1.248.848.3701

www.concrete.org

Specifications for Repair of Concrete in Buildings (ACI 563-18)

An ACI Standard

Reported by ACI Committee 563

Tracy D. Marcotte*, Chair

Jay H. Paul, Secretary

Jeffrey W. Coleman
Peter Emmons
Sidney Freedman
Paul E. Gaudette
Fred R. Goodwin
James K. Hicks

Roger S. Johnston
Kevin R. Krawiec
Carl J. Larosche
Kenneth M. Lozen*
John S. Lund
Marjorie M. Lynch

James E. McDonald
Clyde Porter Jr.
James A. Ragland
Michael M. Sprinkel
Kyle D. Stanish*
David A. VanOcker

David W. Whitmore
Consulting Member
John C. Hukey

*Editorial committee members.

Tony Murray was the first committee chair of ACI Committee 563 and a committee member of ACI 563 at the time of his death in 2016. The committee expresses its appreciation for his friendship and leadership.

Special acknowledgement to Matthew R. Hansen* for his contribution to this Specification.

This is a Reference Specification that the Architect/Engineer can apply to any construction repair and rehabilitation project involving structural concrete by citing it in the Project Specifications. Mandatory requirements and Optional requirements checklists are provided to assist the Architect/Engineer in supplementing the provisions of this Specification, as required or needed, by designating or specifying individual project requirements. The first section covers general construction requirements for all repair Work. The second section covers shoring and bracing of the structure or member to be repaired, and addresses sequencing of repair Work as the structure is unloaded and reloaded. The third section covers concrete removal and preparation of the concrete substrate for repair; and defines common equipment and methods. The next five sections cover materials and proportioning of concrete; proprietary cementitious and polymer repair materials; reinforcement; production, placing, finishing, and curing of repair materials; formwork performance criteria and construction; treatment of joints; embedded items; repair of surface defects; mockups; and finishing of formed and unformed surfaces. Provisions governing testing, evaluation, and acceptance of repair materials as well as acceptance of the repair Work are included. Sections 9 and 10 incorporate by reference two other specifications—ACI 503.7 and ACI 506.2—into this ACI Standard to cover crack repair by epoxy injection and shotcrete, respectively.

Keywords: bracing, cold weather; compressive strength; consolidation; curing; durability; epoxy injection; finish; formwork; grouting; hot weather; inspection; joints; mockups; placing; precast; repair; rehabilitation; reshoring; shoring; shotcrete; slab; steel reinforcement; surface preparation; testing; tolerance; welded wire.

CONTENTS

SECTION 1—GENERAL REQUIREMENTS, p. 2

- 1.1—Scope, p. 2
- 1.2—Interpretation, p. 2
- 1.3—Definitions, p. 3
- 1.4—Referenced standards, p. 4
- 1.5—General procedures, p. 6
- 1.6—Preinstallation conference, p. 6
- 1.7—Submittals, p. 6
- 1.8—Quality assurance, quality control, testing, and inspection, p. 6
- 1.9—Acceptance of repair Work, p. 8
- 1.10—Repair material manufacturer's technical support and field representative, p. 9

SECTION 2—SHORING AND BRACING, p. 9

- 2.1—General, p. 9
- 2.2—Products, p. 10
- 2.3—Execution, p. 10

ACI 563-18 was adopted August 15, 2018, and published September 2018.

Copyright © 2018, American Concrete Institute

All rights reserved including rights of reproduction and use in any form or by any means, including the making of copies by any photo process, or by electronic or mechanical device, printed, written, or oral, or recording for sound or visual reproduction or for use in any knowledge or retrieval system or device, unless permission in writing is obtained from the copyright proprietors.

SECTION 3—CONCRETE REMOVAL AND PREPARATION FOR REPAIR, p. 10

- 3.1—General, p. 10
- 3.2—Products, p. 10
- 3.3—Execution, p. 11

SECTION 4—FORMWORK, p. 12

- 4.1—General, p. 12
- 4.2—Products, p. 12
- 4.3—Execution, p. 13

SECTION 5—REINFORCEMENT AND REINFORCEMENT SUPPORTS, p. 14

- 5.1—General, p. 14
- 5.2—Products, p. 15
- 5.3—Execution, p. 17

SECTION 6—CONVENTIONAL CONCRETE MIXTURES, p. 19

- 6.1—General, p. 19
- 6.2—Products, p. 19
- 6.3—Execution, p. 24

SECTION 7—HANDLING AND PLACING OF CONVENTIONAL CONCRETE, p. 24

- 7.1—General, p. 24
- 7.2—Products, p. 25
- 7.3—Execution, p. 25

SECTION 8—PROPRIETARY CEMENTITIOUS AND POLYMER REPAIR MATERIALS, p. 29

- 8.1—General, p. 29
- 8.2—Products, p. 30
- 8.3—Execution, p. 30

SECTION 9—CRACK REPAIR BY EPOXY INJECTION (ACI 503.7), p. 30

SECTION 10—SPECIFICATION FOR SHOTCRETE (ACI 506.2), p. 30

NOTES TO SPECIFIER (Nonmandatory), p. 30

- General notes, p. 30
- Foreword to checklists, p. 31

MANDATORY REQUIREMENTS CHECKLIST, p. 33

OPTIONAL REQUIREMENTS CHECKLIST, p. 35

SECTION 1—GENERAL REQUIREMENTS

1.1—Scope

1.1.1 This Specification covers repair of concrete in existing structures.

1.1.2 This Specification is incorporated by Contract Documents and provides requirements for Contractor.

1.1.3 This Specification governs for construction within its scope, except other Contract Documents govern if there is a conflict.

1.1.4 This Specification governs if there is a conflict with referenced material and testing standards.

1.1.5 Contractor is permitted to submit written alternatives to any provision in this Specification for consideration.

1.1.6 Do not use this Specification in conjunction with ACI 301, ACI 350.5, or ACI 530.11 unless Contract Documents state that this Specification governs for Work covered by 1.1.1.

1.1.7 Ignore provisions of this Specification that are not applicable to Work.

1.1.8 Values in this Specification are stated in inch-pound units. A companion specification in SI units is available.

1.1.9 The Notes to Specifiers are not part of this Specification.

1.2—Interpretation

1.2.1 Unless otherwise explicitly stated, this Specification shall be interpreted using the following principles:

1.2.1.1 Interpret this Specification consistent with the plain meaning of the words and terms used.

1.2.1.2 Definitions provided in this Specification govern over the definitions of the same or similar words or terms found elsewhere.

1.2.1.3 Whenever possible, interpret this Specification so that its provisions are in harmony and do not conflict.

1.2.1.4 Headings are part of this Specification and are intended to identify the scope of the provisions or sections that follow. If there is a difference in meaning or implication between the text of a provision and a heading, the meaning of the text governs.

1.2.1.5 Footnotes are part of this Specification. The meaning of the provision text governs in the event of a difference in meaning or implication between the provision text and a footnote to that provision.

1.2.1.6 Where a provision of this Specification involves two or more items, conditions, requirements, or events connected by the conjunctions “and” or “or,” interpret the conjunction as follows: “and” indicates that all the connected items, conditions, requirements, or events apply; “or” indicates that the connected items, conditions, requirements, or events apply singularly.

1.2.1.7 The use of the verbs “may” or “will” indicates that the Specification provision is for information to the Contractor.

1.2.1.8 The phrase “as indicated in Contract Documents” means the specifier included the provision requirements in Contract Documents.

1.2.1.9 The phrase “unless otherwise specified” means the specifier may have included an alternative to the default requirement in Contract Documents.

1.2.1.10 The phrase “if specified” means the specifier may have included a requirement in Contract Documents for which there is no default requirement in this Specification.