

TRRC - ACI DOCUMENT REVIEW SUMMARY

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
KP	116	116R-00	Cement and Concrete Terminology	73		There are many terms that should be included that are not - too numerous to mention, but as an example, this document does not include shotblasting, scarifiers, or hydrodemolition. Also, there are many definitions that do not match ICRI's Terminology.	A recommendation should be made to committee 116 from TRRC, to include many more repair terms. To ease the burden of this work, they could incorporate ICRI's terminology (which has been approved through ICRI's TAC review process)
JMD	201	201.1R-92	Guide for Making a Condition Survey of Concrete	16	1 - Introduction; 2 - Check list; 3 - Definitions and photographs	"repair" appears once in this document	No action
JMD	201	201.2R-01	Guide to Durable Concrete	41	1- Freezing and thawing; 2- Aggressive chemical exposure; 3- Abrasion; 4- Corrosion of metals and other materials embedded in concrete; 5- Chemical reactions of aggregates; 6- Repair of concrete; 7- Use of protective-barrier systems to enhance concrete durability; 8- References; Appendix A- Method for preparing extract for analysis of water-soluble sulfate in soil	Chapter 6 is a 2-page summary of concrete repair basics. All of the topics included in this summary are addressed in much greater detail in the ACI Concrete Repair Guide (546R-04). Similarly, the 2-page discussion of protective barrier systems to enhance concrete durability (Chapter 7) is very limited compared to the detail in ACI 546R-04. Both chapters appear to be outside the 201 mission to "develop and report information to ensure the production of durable concrete" and are unnecessary duplications of more comprehensive information in other ACI documents, particularly 546R-04.	Chapters 6 and 7 should be deleted from 201.2R-01 with references to 546R-04 as appropriate
JMD	207	204.3R-94	Practices for Evaluation of Concrete in Existing Massive Structures for Service Conditions	16	1-Introduction; 2-Preinspection and In-Service Inspection; 3-In-situ Condition Surveys and Testing; 4-Sampling and Laboratory Testing; 5-Damage; 6-Report; 7-references	"repair" appears several times in this document generally in the context that structure evaluation is required to determine the need for repair, or the condition of any repairs should be included as part of inspection reports	No action
JMD	207	207.1R-96	Mass Concrete	42	1- Introduction and historical developments; 2- Materials and mix proportioning; 3- Properties; 4- Construction; 5- Behavior; 6- References; Appendix-Metric examples	"repair" does not appear this document	No action

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
JMD	207	207.2R-95	Effect of Restraint, Volume Change, and Reinforcement on Cracking of Mass Concrete	26	1- Introduction; 2- Volume change; 3- Properties; 4- Restraint; 5-Crack widths; 6- Application; 7- References; Appendix- Notation and Metric conversions	"repair" appears once in this document with a reference to 224.1R for details on evaluation and repair of cracks	No action
JMD	207	207.4R-93	Cooling and Insulating Systems for Mass Concrete	22	1-Introduction; 2-Need for temperature control; 3-Precooling systems; 4-Post-cooling systems; 5-Surface insulation; 6-Expected trends; 7- references	The only mention of "repair" is in connection with cooling pipes	No action
JMD	207	207.5R-99	Roller-Compacted Mass Concrete	47	1-Introduction; 2-Materials and mixture proportioning; 3-Properties of hardened RCC; 4- Design of RCC dams; 5-Construction of RCC dams; 6-Quality control of RCC; 7-General references and information sources	No mention of concrete "repair"	No action
JMD	210	210.1R-94	Compendium of Case Histories on Repair of Erosion-Damaged Concrete in Hydraulic Structures	33	1-Introduction; 2- Cavitation-erosion case histories; 3- Abrasion-erosion case histories; 4- Chemical attack-erosion case histories; 5- Project reference List	This compendium of case histories provides information on damage that has occurred to hydraulic structures and the various methods of repair that have been used. Summaries of repair techniques and subsequent performance are intended to aid in avoidance of oversights in design and construction of hydraulic structures and provide guidance in the treatment of future problems.	No action
JMD	210	210R-93	Erosion of Concrete in Hydraulic Structures	24	1-Causes of erosion; 2-Erosion by cavitation; 3- Erosion by abrasion; 4-Erosion by chemical attack; 5- Control of cavitation erosion; 6 Control of abrasion erosion; 7-Control of erosion by chemical attack; 8-Periodic inspections and corrective action; 9-Repair methods and materials; 10-References	Approximately 3 pages (Chap 9) of the 24 page document is devoted to repair. Discussion is generally limited to the ability of a variety of materials to resist cavitation and abrasion erosion resulting from high velocity flow and waterborne debris. Material requirements and repair techniques for hydraulic structures are somewhat unique; therefore, this brief summary of pertinent considerations appears appropriate for this document. References are provided for additional details on each material and method.	No action

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
KP	212	212.3R-04	Chemical Admixtures for Concrete	30	1- General Information; 2- Air-Entraining Admixtures; 3- Accelerating Admixtures; 4- Water-Reducing and Set-Controlling Admixtures ; 5- Admixtures for Flowing Concrete; 6- Miscellaneous Admixtures; 7- References	Repair only appears once in this document in the following paragraph:"Prepackaged mortar formulations are available that have an initial time of setting of 1 to 4 min and a final setting time of 3 to 10 min. They are used to seal leaks in below-grade structures, for patching, and for emergency repair. The ultimate strength of such mortar is much lower than if no accelerating admixture had been added."	No action needed, unless reference inserted to proper document detailing such mortars and their uses.
KP	212	212.4R-04	Guide for the Use of High-Range Water-Reducing Admixtures (Superplasticizers) in Concrete	13	1- General Information; 2- Effects of High Range Water-Reducing Admixtures; 3- Effects on Freshly Mixed Concrete; 4- Effects on Hardened Concrete; 5- Typical Applications of	Repair only appears twice in this document: Once, in reference to low w/c ratio and how it can be beneficial to various grouts and prepackaged	No action necessary
FG	216	216R-2	Guide for Determining the Fire Endurance of Concrete Elements	48	Chapter 1-General Chapter 2-Fire endurance of concrete slabs and beams, Chapter 3-Fire endurance of walls, Chapter 4-Reinforced concrete columns, Chapter 5-Properties of steel at high temperatures, Chapter 6-Properties of concrete at high temperatures, Chapter 7- Temperature distribution within concrete members exposed to a standard fire, Chapter 8- Examples, Chapter 9-References, Appendix- Design of building elements for prescribed level of fire safety	No repairs are covered. No mention of the words "repair", "rehabilitation", "retrofit", "damage", or "restor*" in this document.	Leave document status as is. Repair situations should comply with original design parameters regarding fire protection.
FG	216	ACI 216.1-97 / TMS 0216.1-97	Standard Method for Determining Fire Resistance of Concrete and Masonry Construction Assemblies	26	Chapter 1—General, Chapter 2—Concrete, Chapter 3—Concrete masonry, Chapter 4—Clay brick and tile masonry, Chapter 5—Effects of finish materials on fire resistance, Chapter 6—References, Appendix A Fire resistance of concrete masonry protected steel columns, Appendix B Fire resistance of clay masonry protected steel columns, Appendix C CONVERSION FACTORS—INCH-POUNDS TO SI (METRIC)	No repairs are covered. No mention of the words "repair", "rehabilitation", "retrofit", "damage", or "restor*" in this document.	Leave document status as is. Repair situations should comply with original design parameters regarding fire protection.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
JMD	221	221.1R-98	State-of-the-Art Report on Alkali-Aggregate Reactivity	31	1 - Introduction; 2 - Manifestations of distress due to alkali-silica reactivity; 3 - alkali-silica reactivity mechanisms; 4 - Petrography of alkali-silica reactive aggregate; 5 - Measures to prevent ASR; 6 - Methods to evaluate potential for expansive ASR; 7 - Manifestations of distress due to alkali-carbonate reactivity; 8 - ACR mechanisms; 9 - Measures to prevent ACR; 10 - Methods to evaluate potential for expansive ACR; 11 - Evaluation and repair of structures affected by AAR; 12 - References	Repair of structures affected by AAR is briefly summarized in Chapter 11 (1 1/2 pages) with extensive references to other documents for details. AAR often requires unique techniques for maintenance and repair; therefore, Chapter 11 appears appropriate for this document. There is minimal overlap and no obvious conflicts with other ACI repair-related documents	No action
JMD	221	221R-96	Guide for Use of Normal Weight and Heavyweight Aggregates in Concrete	29	1 - Introduction; 2 - Properties of hardened concrete influenced by aggregate properties; 3 - Properties of freshly mixed concrete influenced by aggregate properties; 4 - Effects of processing and handling of aggregates on properties of freshly mixed and hardened concrete; 5 - Quality assurance; 6 - Marginal and recycled aggregates; 7 - Heavyweight aggregates; 8 - References	"repair" does not appear in this document	No action
JP	222	222.1-96	Provisional Standard Test Method for Water-Soluble Chloride Available for Corrosion of Embedded Steel in Mortar and Concrete Using the Soxhlet Extractor			Repair is not covered in this document	No change is required
JP	222	222.2R-01	Corrosion of Prestressing Steels			Repair is not covered in this document but reference is made to ACI 423.4R for repair methods for unbonded tendons. There is no reference to ACI 546.	No change is required except to reference ACI 546.
JP	222	222.3R-03	Design and Construction Practices to Mitigate Corrosion of Reinforcement in Concrete Structures			The repair to defects of epoxy coated reinforcing is briefly discussed with reference to ACI 301. Appropriate reference is given to ACI 546 for repair methodology. This document correctly indicates that repair alone does little to address the causes of deterioration due to corrosion unless something is done to mitigate or stop the corrosion mechanism. This document provides guidance in this regard.	No change is required. It is an excellent supplement to ACI 546 and should be used as a reference when developing concrete repairs.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
JP	222	222R-01	Protection of Metals in Concrete Against Corrosion			This document discusses methods to control corrosion which is an important aspect of any concrete repair program. Procedures to identify corrosive environments and active corrosion are included in this document which must be considered in concrete repair programs. The document does discuss in general terms the methodology for repairs especially in Chapter 5 with reference to ACI 546.	This document is an excellent supplement to ACI 546 and should be used as a reference when developing concrete repairs. It emphasizes methods to control and prevent future corrosion. I do not think that there are any conflicts with 546 or that repair is covered too much but it should be carefully reviewed.
RP	224	224.1R	Causes, Evaluation and Repair of Cracks in Concrete Structures	21		Document summarizes the causes, evaluation and repair of cracks.	This is a basic document that should be referenced by all committees when reference is made to crack repair. It should remain with the committee, but be under the purview of TRRC.
RP	224	224.2R	Cracking of Concrete Members in Direct Tension	12		Document summarizes the situations in which concrete members may be in tension and the causes of this type of cracking.	This document is in the process of being eliminated with the material being integrated into the main committee report 224R.
RP	224	224.3R	Joints in Concrete Construction	44		Document summarizes the design of joints in all types of concrete construction including type of joint and spacing to be considered.	Leave the document with the committee.
RP	224	224R	Control of Cracking in Concrete Structures	46		Document summarizes the mechanisms that cause cracking and methods that can be used in design and construction to mitigate cracking.	This is a basic document that should be referenced by all committees when discussing the cause of cracks. It should remain with the committee.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
FG	225	ACI 225R-99	Guide to the Selection and Use of Hydraulic Cements	30	Chapter 1—Introduction, Chapter 2—Cement types and availability, 2.1—Portland and blended hydraulic cements 2.2—Special-purpose cements Chapter 3—Cement chemistry, 3.1—Portland cements 3.2—Blended hydraulic cements 3.3—Shrinkage-compensating expansive cements 3.4—Calcium-aluminate cements Chapter 4—Influence of chemical and mineral admixtures and slag on the performance of cements, 4.1—Air-entraining admixtures 4.2—Chemical admixtures 4.3—Mineral admixtures 4.4—Ground granulated blast-furnace slags Chapter 5—Influence of environmental conditions on the behavior of cements, Chapter 6—Influence of cement on properties of concrete, 6.1—Thermal cracking 6.2—Placeability 6.3—Strength 6.4—Volume stability 6.5—Elastic properties 6.6—Creep 6.7—Permeability 6.8—Corrosion of embedded steel 6.9—Resistance to freezing and thawing 6.10—Resistance to chemical attack 6.11—Resistance to high temperatures 6.12—Cement-aggregate reactions 6.13—Cold Chapter 7—Cement storage and delivery, Chapter 8—Sampling and testing of hydraulic cements for conformance to specifications, 8.1	No repairs are covered. Mention of the word "repair" is made in Section 2.2 describing some applications for special cements (T III, CA, MgPO ₄ , Ultrafine), Damage is used in section 6 regarding some of the deterioration mechanisms of cementitious materials.	Perhaps the descriptions of different cement types (section 2). might be useful as a reference in the Repair code Also description of the physical and chemical parameters of cementitious materials would also be useful as a reference (sections 3, 4, 5, and 6).
RP	228	228.2R	Nondestructive Test Methods for Evaluation of Concrete Structures	62		Document summarizes methods to evaluate the condition of existing concrete construction using various electro/mechanical/chemical methods.	This document should be within TRRC purview as it relates to evaluation of existing structures.
RP	228	228.1R	In-place Methods to Estimate Concrete Strength	44		Document summarizes methods to estimate the strength of concrete. It addresses the issue for both new construction relative to form removal and issues when strength is in question in existing construction.	Leave the document with the committee.
PE	229					No repair in this document	
PE	230					This document not in MCP	
KP	232	232.1R-00	Use of Raw or Processed Natural Pozzolans in Concrete	24	1- General; 2- Effects of Natural Pozzolan on Concrete Properties; 3- Specification, Test Methods, Quality Control and Quality Assurance; 4- Concrete Production Using Natural Pozzolans; 5- Concrete Applications for Natural Pozzolans; 6- Other Uses of Natural Pozzolans; 7- References	"repair" does not appear this document	No action

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
KP	232	232.2R-03	Use of Fly Ash in Concrete	41	1- General; 2- Fly Ash Composition; 3- Effects of Fly Ash on Concrete; 4- Concrete Mixture Proportioning; 5-Fly Ash Specifications, Test Methods and Quality Assurance/Control; 6-Fly Ash in Concrete Construction; 7- Fly Ash in Concrete Products; 8 - Other Uses of Fly Ash; 9 - References; Appendix- Rapid Quality Control Tests	"Repair" appears once in this document with a reference to 207.5R, which refers to the construction and repair of RCC dams	No action
KP	234	234R-96	Guide for the Use of Silica Fume in Concrete	51	1-Introduction; 2-Physical Properties and Chemical Composition of Silica Fume; 3- Mechanism by which Silica Fume Modifies Cement Paste; 4-Effects of Silica Fume on Properties of Fresh Concrete; 5-Effects of Silica Fume on Properties of Hardened Concrete; 6-Applications of Silica Fume; 7- Proportioning Silica Fume Concrete; 8- Specifications; 9- Working with Silica Fume in Field Concrete; 10- Research Needs; 11 - References	"Repair" appears several times in this document generally in the context of how silica fume concrete has been used in repairs, because it provides things such as abrasion/erosion resistance, chemical attack resistance, etc. It also appears in the following section: "Research is needed to develop better test methods, to investigate the performance of concrete under field conditions, and to determine construction practices that produce the best results in terms of resistance to corrosion. A related issue of particular interest in North America is the repair of deteriorated structures. Research is needed to develop repair methods that will not simply create new corrosion cells in different locations. Silica-fume concrete may well have a role to play in these repairs."	No action needed on the general references to silica fume concrete being used in repairs. May want to remove "A related issue of particular interest in North America is the repair of deteriorated structures. Research is needed to develop repair methods that will not simply create new corrosion cells in different locations. Silica-fume concrete may well have a role to play in these repairs."
LK	301	ACI 301-05	Specifications for Structural concrete	47	1-general requirements; 2 formwork and formwork accessories; 3-reinforcement; 4- concrete mixtures; 5-handling, placing, constructing; 6-architectural; 7- lightweight; 8- mass; 9-prestressed; 10-shrinkage-compensating	See details below	See details below
LK	301	301-05	Specifications for Structural concrete		1.6.5	Tests on hardened concrete in place (limited techniques)	keep section 1.6.5 as is, reference repair spec when ready
LK	301	301-05	Specifications for Structural concrete		1.7.1.3 & 4	Repair rejected concrete work by removing and replacing or by reinforcing with additional construction...by Architect/Engineer	keep 1.7.1.3 & 4 as is
LK	301	301-05	Specifications for Structural concrete		1.7.4.2	Action required when strength is potentially deficient. Section gives rehabilitation procedure.	This section needs to reference a repair specification

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
LK	301	301-05	Specifications for Structural concrete		1.7.5.2	Action required when durability is potentially deficient	keep until repair spec is ready.
LK	301	301-05	Specifications for Structural concrete		3.3.2.8.b	repair of bar coatings -- epoxy repair prior to concrete placement	keep as is
LK	301	301-05	Specifications for Structural concrete		5.3.7.3	Repair of surface defects other than tie holes. Gives specific repair technique	keep section 5.3.7.3 as is for now. Change language to "repair pursuant to specifications given in aci 564 Repair Specifications". This really should reference ACI repair guide and ICRI guides.
LK	301	301-05	Specifications for Structural concrete		5.3.7.6	Repair materials other than site-mixed portland cement mortar. Gives ASTM epoxy references	needs to reference materials guide and application procedures
LK	301	301-05	Specifications for Structural concrete		6.3.6	Repair of tie holes and surface defects (gives architectural finish requirements)	keep 6.3.6 Until an architectural repair spec is done
JP	302	302.1R-04	Guide for Concrete Floor and Slab Construction			Indicates that grinding, planing, removal and replacement can be used as remedial measures for slabs-on-grade. For suspended slabs, remedial measures are generally limited to grinding or use on an underlayment or topping material. No specific repair methods are given but the document indicates that the repair documents should clearly identify acceptable corrective methods. The document references ACI 222 and 222.1R for crack repairs. ACI 546 is not referenced.	No changes are required except that ACI 546 should be referenced.
KP	303	303.1-97	Standard Specification for Cast-in-Place Architectural Concrete	10	1-General; 2-Concrete for Architectural Cast-In-Place Construction; 3-Reinforcement, Tie wire, and Bar Supports; 4-Formwork for Architectural Concrete; 5-Architectural Treatments; 6-Miscellaneous	"Repair" appears several times in this document, in the context of surface defects that may need to be repaired.	As this is a specification, it does not get into how to repair the defects, so no action is necessary.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
PG	303	303.1-97	Standard Specification for Cast-in-Place Architectural Concrete	10	Specification Checklist; 1 - General; 2 - Concrete for Architectural Cast-in-Place Construction; 3 - Reinforcement, tie-wire and bar supports; 4 - Formwork for Architectural Concrete; 5 - Architectural Treatments; 6 - Miscellaneous	Repair is referred to generally regarding correction of aesthetic and casting problems such as contrasts, blemishes, etc. Mockups and matching for repair to the architectural concrete is also mentioned. There should be a reference to ACI 546R-04 for concrete repair. There is also mention of sealers and joint sealants which can be referenced to ACI 515.1R and AIC 504R.	References to ACI 504R, ACI 515.1R and ACI 546R should be added.
KP	303	303R-04	Guide to Cast-in-Place Architectural Concrete Practice	32	1-Introduction; 2-Architectural Considerations; 3-Structural Considerations; 4-Forms; 5-Reinforcement; 6-Concrete Materials and Mixture Proportioning; 7-Placing and Consolidation; 8- Curing; 9- Treated Architectural Surfaces; 10- Finishing and Final Cleanup; 11 - References; Appendix - Architectural Concrete Photos	"Repair" appears several times in this document, in the context of surface defects that may need to be repaired. "Blemish repair" is the title of a whole section.	The "blemish repair" section does get very specific as to how to repair these surface defects. It should be left as is, since there is no other better section in one of the "repair" committee documents that I could find.
PG	303	303R-04	Guide to Cast-in-Place Architectural Concrete Practice	29	1- Introduction; 2- Architectural considerations; 3- Structural considerations; 4- Forms; 5- Reinforcement; 6- Concrete materials and mixture proportioning; 7- Placing and consolidation; 8- Curing; 9- Treated architectural surfaces; 10- Finishing and final cleanup; 11- References; Appendix A- Architectural concrete photos	Repair is discussed in relation to correcting construction problems. Section 2.5.4, par 4 should include a reference to ACI 546R. Emphasis on mockups throughout the document is good. Section 3.3 which discusses cracking should correspond with refer to greater detail in ACI 224. Section 3.4 Joints should correspond with and mention that ACI 504 has more detail. Chapter 10 Finishing and Final Cleanup has several references to repair regarding blemishes, filling tie holes, etc. This chapter should correspond to recommendations of ACI 546R and ACI 515. Description of repair may be simplified or removed, and should refer to ACI 546 and 515 for more comprehensive information.	References to repair of blemishes and construction problems should reference ACI 546R, ACI 515, ACI 504. The cracking discussion (3.3) should correspond to and refer to ACI 224. Section 3.4 should correspond to and refer to ACI 504. Chapter 10 needs some editing to correspond to ACI 546R and other repair documents and references to repair need to be added.
PC	304	304.1R-92	Guide for the Use of Pre-placed Aggregate Concrete for Structural and Mass Concrete Applications	19	1 - Intro, 2 - mat'l's & proportioning, 3 - Equipment, 4 - construction procedure, 5 - temp control, 6 - quality assurance and control, 7 - conclusion, 8 - references	Mentions use in construction, but most examples are of repairs. PPAC is currently covered in 546 repair guide by referring to this 304 document.	Need 2 separate documents, construction with PPAC and repair with PPAC. The jurisdiction for the repair version of 304.1R should belong to 546

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
PC	304	304.2R-96	Placing Concrete by Pumping Methods	25	1 - Intro, 2 - Equipment, 3 - Pipeline, 4 - proportioning, 5 - Field practices, 6 Field control, 7 References	No repairs are covered.	Leave document status as is.
PC	304	304.3R-96	Heavy-weight Concrete Measuring, Mixing, Transporting and Placing	8	1 - General considerations, 2 - Materials, 3 - Concrete characteristics, 4 - Equipment, 5 - Formwork, 6 - Placement, 7 - QC, 8 - References	No mention of the word repair in this short document.	Leave document status as is.
PC	304	304.5R-91	Batching, Mixing, and Job Control of Lightweight Concrete	9	1 - Intro, 2 - Measuring & batching, 3 - Mixing, 4 - Job controls, 5 - References	No mention of the word repair in this short document.	Leave document status as is.
PC	304	304.6R-91 (reapproved 1997)	Guide for the Use of Volumetric-Mixing and Continuous-Mixing Concrete Equipment	14	1 - Intro, 2 - Equipment, 3 - Operations, 4 - Applications, 5 - QC & Testing, 6 - Operational Precautions, 7 - References	Chapter 1 mentions use in highway and bridge deck repairs	probably best to leave this material in Committee 304 domain
PC	304	304R-00	Guide for Measuring, Mixing, Transporting and Placing Concrete	41	1 - Intro, 2 - control, handling, storage, 3 - measurement, batching, 4 - mixing, transporting, 5 - placing, 6 - forms, joint prep, finishing, 7 - Pre-placed Aggregate Concrete, 8 - Underwater placing, 9 - pumping, 10 - conveying, 11 - heavyweight and radiation shielding, 12 - lightweight structural, 13 - volumetric & contin mixing equipment, 14 - references	Chapter 7, pp20-24, covers the topic of PPAC. Underwater repairs are also mentioned.	Except chapter 7, jurisdiction for all other chapters can be left as is. Chapter 7, PPAC, refers to a repair method, generally not a construction method, so Chapter 7 should be moved to 546R repair guide, 546.2R underwater repairs, or to a new document similar to 304.1R.
KP	309	309.1R-93	Behavior of Fresh Concrete During Vibration	19	1-History of Concrete Vibration; 2-Influence of Rheology on the Consolidation of Fresh Concrete; 3-Mechanisms of Concrete Vibration; 4- References	No mention of concrete "repair"	No action
KP	309	309.2R-98	Identification and Control of Consolidation Related Surface Defects in Formed Concrete	11	1-General; 2-Factors Causing Effects; 3-Surface Blemishes; 4-Minimizing Surface Effects; 5-Consolidation of Pre-placed aggregate Concrete; 6-Conclusion; 7-Surface Condition Outline; 8- References	Repair is only mentioned a couple of times in the context that they are to be avoided by doing things right in the first place.	No action
KP	309	309.5R-00	Compaction of Roller-Compacted Concrete	15	1-Introduction; 2-Mixture proportions; 3-Effects on Properties; 4-Equipment; 5-Placement and Compaction; 6-Construction Control; 7-References	Repair is only mentioned once, in the following sentence:"Localized compaction for repair of lift surface damaged by equipment operation."	No action necessary
KP	309	309R-05	Guide for Consolidation of Concrete	36	1-General; 2-Effect of Mixture Proportions on Consolidation; 3-Methods of Consolidation; 4- Consolidation of Concrete by Vibration; 5- Equipment for Vibration	Repairs are only mentioned here in the context that surface defects caused by lack of consolidation are difficult to repair, and should be avoided.	No action necessary
FG	311	ACI 311.1R-99	ACI Manual of Concrete Inspection	1	N/A	Just a description of committee documents.	Does not appear useful in and of itself.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
FG	311	ACI 311.4R-05	Guide for Concrete Inspection		Chapter 1—Introduction, 1.1—Scope 1.2—Philosophy 1.3—General 1.4—Definitions 1.5—Categories of inspection 1.6—Inspection team Chapter 2—Responsibilities, 2.1—Scope 2.2—Owner's Responsibilities 2.3—Architect/engineer's inspection responsibilities 2.4—Owner's inspection organization responsibilities 2.5—Contractor's inspection responsibilities 2.6—Manufacturer's or fabricator's inspection responsibilities Chapter 3—Planning for inspection, 3.1—Scope 3.2—Written inspection plan 3.3—Building code requirements for special inspections 3.4—Preconstruction conferences 3.5—Meetings 3.6—Qualifications of inspection and testing personnel 3.7—Recommendations for inspection and testing 3.8—Reporting and evaluating inspection and test results Chapter 4—References, Appendix I—Expanded checklist of inspection attributes, Appendix II—Synopsis of ACI 311.5	Sections 1.2, 1.3, 1.4, 1.5, 1.6, 2, 3, except for 3.3 and 3.6, Table 1 beginning with III, 3.7 with editing, 3.8 Appendix 1 section on preconstruction testing of materials parts 1-9, bag storage, and the section on post placement inspection depending on material and application method are relevant to a Repair Code.	Some minor changes are needed, but most of the document could be excerpted and dropped into the appropriate sections on repair. Edit and excerpt as needed, but do should not be under the jurisdiction of the Repair Code as it mainly addresses new construction.
FG	311	ACI 311.5-04	Guide for Concrete Plant Inspection and Testing of Ready-Mixed Concrete	6	Chapter 1—Plant inspection of ready-mixed concrete, Chapter 2—Testing of ready-mixed concrete, Chapter 3—References	No repairs are covered. No mention of the words "repair", "rehabilitation", "retrofit", "damage", or "restor*" in this document.	
FG	311	SP2	ACI Manual of Concrete Inspection	209	Not a part of MCP	Chapter 11 Correction of defects in newly hardened concrete and repairs of older concrete, Chapter 12 the section on two course slabs, Chapter 14 sections on repairs and final acceptance, Chapter 15 sections on PPAC, US, and shotcrete, and Chapter 16 on pressure grouting and base plate grouting	Edit and excerpt appropriate sections.
LK	313	ACI 313-97	Standard Practice for Design and Construction of Concrete Silos	19	1-general; 2-materials; 3-construction requirements; 4-design; 5-concrete stave industrial silos; 6-posttensioned concrete silos; 7-stacking tubes; 8-references	Repair is not mentioned	Do nothing.
JP	315	315-99	Details and Detailing of Concrete Reinforcement			No specific concrete repairs are discussed except for the repair of damaged corrosion-resistant coatings on reinforcing.	No changes to this document are required.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
RP	318	318	Building Code Requirements for Structural Concrete and Commentary	430		Document is the represents the legal requirements for designing structural concrete in North America and many other foreign countries. It is primarily geared to new construction.	Leave document with committee.
MS	325	32510R-95					No action
MS	325	32511R-01					No action
MS	325	32512R-02					No action
PE	330				Chapter 6—Maintenance and repair, p. 330R-15 6.1—Introduction 6.2—Surface sealing –in core documents 6.3—Joint and crack sealing- in core documents 6.4—Full-depth repair- not in core documents in the detail required 6.5—Undersealing and leveling- not in core documents 6.6—Overlay not in core documents in the detail required 6.7—Parking lot cleaning		
PE	332				Chapter 11-Repair of surface defects, page 332R.29 This chapter details methods of fixing new construction defects (not covered in core documents)		
PG	336	336.1-01	Specification for the Construction of Drilled Piers	22	1- General requirements; 2- Products; 3- Execution; Preface to specification checklist; Mandatory requirements checklist; Optional Requirements checklist; Submittal checklist	"repair" is only mentioned once in document and refers to placing of reinforcing steel	No action
PG	336	336.2R-02	Suggested Analysis and Design Procedures for Combined Footings and Mats	21	1- General; 2- Soil structure interaction; 3- Distribution of soil reactions; 4- Combined footings; 5-Grid foundations and strip footings supporting more than two columns; 6- Mat foundations; 7- Summary; 8- References	"repair" does not appear in document	No action
PG	336	336.3R-98	Design and Construction of Drilled Piers	29	1-General; 2-General considerations; 3-Design; 4-Construction methods; 5-Construction inspection and testing; 6-References	"repair" appears only once and refers to repair or alteration of existing pier caps	No action
LK	341	ACI 341.2R-97	Seismic Analysis and Design of Concrete Bridge Systems	25	1-Introduction; 2-codes; 3-analysis; 4-modeling; 5-design; 6-references	Repair is not mentioned	Do nothing.
PC	342	none	none			no published docs	No docs.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
JP	343	343R-95	Analysis and Design of Reinforced Concrete Bridge Structures.			There is no mention of concrete repair in this document. The only reference to repair is to the repair of damaged coatings with ASTM A 767 (for zinc) and ASTM A 775 (epoxy).	No changes to this document are required.
MS	345	3451R-92					No action
MS	345	3452R-98					No action
MS	345	345R-91					No action
JMD	346	346-01	Specification for Cast-in-Place Concrete Pipe	5	1 - General; 2 - Products; 3 - Execution	Very brief discussion of crack repairs	No action
JP	349	349.1R	Reinforced Concrete Design for Thermal Effects on Nuclear Power Plant Structures			The is no reference to repair in this document.	No changes to this document are required.
JP	349	349.2R-97	Embecment Design Examples			The is no reference to repair in this document.	No changes to this document are required.
JP	349	349.3R-02	Evaluation of Existing Nuclear Safety-Related Concrete Structures			This document discusses methods to evaluate nuclear structures including testing techniques, evaluation criteria and acceptance criteria. Chapter 8 covers repair. No specific techniques are provided but 1999 Concrete Repair Manual is referenced indicating that there are methods cited that are well suited for nuclear power plants. ACI 546 is not specifically referenced. This chapter includes a brief discussion of selection criteria of a repair procedure, materials, required documentation, the qualifications of the craftsmen performing the work as well as other issues.	I think that Chapter 8 in this documents needs to be carefully reviewed for consistency with generally acceptable repair methods and procedures. This should be done by individuals with repair expertise in conjunction with representative of committee 349.
JP	349	349-01/349R-01	Code Requirements for Nuclear Safety Related Concrete Structures and Commentary			Repair is not covered in this document.	No changes to this document are required.
LK	350	ACI 350.1-01	Tightness testing of environmental engineering concrete structures	23	1-tightness testing of tanks; 2- hydrostatic test; 3- surcharged hydrostatic test; 4- pneumatic test; 5- combination hydrostatic-pneumatic test; 6- references	Repair is not mentioned	Do nothing.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
LK	350	ACI 350.2R-04	Concrete Structures for Containment of Hazardous Materials	17	1-general; 2-concrete design and proportioning; 3-waterstops, sealants and joints; 4-construction considerations; 5-liners and coatings; 6-secondary containment; 7-leak detection; 8-references	section 3.2.4 Sealant repair, short paragraph saying replace like original.	Do nothing.
LK	350	ACI 350R-89	Environmental Engineering Concrete Structures	24	1-special requirements; 2-structural design considerations; 3-materials, mixture proportioning & testing; 4-construction; 5-protection against chemicals; 6 references	Repair is not mentioned	Do nothing.
FG	351	ACI 351.1R-99	Grouting between Foundations and Bases for Support of Equipment and Machinery	18	Chapter 1—Introduction, 1.1—General, 1.2—Definitions, 1.3—Grout requirements, 1.4—Evolution of materials, Chapter 2—Properties of grout, 2.1—General, 2.2—Hydraulic cement grouts, 2.3—Epoxy grouts, Chapter 3—Requirements of materials for grout, 3.1—General, 3.2—Hydraulic cement grouts, 3.3—Epoxy grouts, Chapter 4—Testing of grout, 4.1—General, 4.2—Hydraulic cement grouts, 4.3—Epoxy grouts, 4.4—Performance evaluation test, Chapter 5—Grouting considerations for foundation design and detailing, 5.1—General, 5.2—Machine or equipment bases, 5.3—Concrete foundation, 5.4—Anchorage design, 5.5—Clearances, Chapter 6—Preparation for grouting, 6.1—General, 6.2—Anchor bolt, 6.3—Concrete surface preparation, 6.4—Metal surfaces, 6.5—Formwork, 6.6—Safety and handling of epoxies, Chapter 7—Grouting procedures, 7.1—Consistency, 7.2—Temperature, 7.3—Mixing, 7.4—Placing, 7.5—Removal of excess material, Chapter 8—Curing and protection, 8.1—Hydraulic cement grouts, 8.2—Epoxy grouts, Chapter 9—Construction engineering and testing, 9.1—General, 9.2—Hydraulic cement grouts, 9.3—Epoxy gro	No repairs are covered except for repair due to shim removal is briefly mentioned. No mention of the words "rehabilitation", "retrofit", or "restor*" in this document. "Damage" is mentioned in regards to freeze thaw action on freshly placed grout and the improved chemical resistance of epoxy grouts in situations where cementitious grouts would be damaged.	Since grouts are frequently used as repair materials or otherwise placed in contact with hardened concrete, this document should be referenced regarding the types testing and construction practices of grouts. It is specifically written for the application of grouts for load transfer in equipment foundations, so little could be extracted for insertion into a Repair Code.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
FG	351	ACI 351.2R-94	Foundations for Static Equipment	30	Chapter 1-Introduction, 1.1-Background, 1.2-Purpose, 1.3-Scope, Chapter 2-Foundation types, 2.1-General considerations, 2.2-Typical foundations, Chapter 3-Design criteria, 3.1-Loading, 3.2-Design strength/stresses, 3.3-Stiffness/deflections, 3.4-Stability, Chapter 4-Design methods, 4.1-Available methods, 4.2-Anchor bolts and shear devices, 4.3-Bearing stress, 4.4-Pedestals, 4.5-Sail pressures, 4.6-Pile loads, 4.7-Foundation design procedures, Chapter 5-Construction considerations, 5.1-Subsurface preparation and improvement, 5.2-Foundation placement tolerances, 5.3-Forms and shores, 5.4-Sequence of construction and construction joints, 5.5-Equipment installation and setting, 5.6-Grouting, 5.7-Materials, 5.8-Quality control, Chapter 6--References, 6.1-Recommended references, 6.2-Cited references, Glossary, Metric (SI) conversion factors	Section 3.2.3 discusses briefly adhesive anchors, which are common in repair situation. Several mentions of repair occur, but no detailed discussion except to imply that repairs must meet design requirements.	Very little to be gained by inclusion and little to reference in Repair Code.
FG	351	ACI 351.3R-04	Foundations for Dynamic Equipment	63	Chapter 1—Introduction, 1.1—Background, 1.2—Purpose, 1.3—Scope, 1.4—Notation, Chapter 2—Foundation and machine types, 2.1—General considerations, 2.2—Machine types, 2.3—Foundation types, Chapter 3—Design criteria, 3.1—Overview of design criteria, 3.2—Foundation and equipment loads, 3.3—Dynamic soil properties, 3.4—Vibration performance criteria, 3.5—Concrete performance criteria, 3.6—Performance criteria for machine-mounting systems, 3.7—Method for estimating inertia forces from multicylinder machines, Chapter 4—Design methods and materials, 4.1—Overview of design methods, 4.2—Impedance provided by the supporting media, 4.3—Vibration analysis, 4.4—Structural foundation design and materials, 4.5—Use of isolation systems, 4.6—Repairing and upgrading foundations, 4.7—Sample impedance calculations, Chapter 5—Construction considerations, 5.1—Subsurface preparation and improvement, 5.2—Foundation placement tolerances, 5.3—Forms and shores, 5.4—Sequence of construction and construction joints, 5.5—Equipment installation and setting, 5.6—Grouting, 5.7—Concrete materials, 5.8—	The very detailed discussion contained in this document of dynamic and vibrational forces transmission and distribution would likely be useful in explanation of failure analysis. An entire section (4.6) is devoted to repair and upgrade of foundations and some discussion in 5.1 regarding improvements to subsurface conditions.	Section 4.6 and portions of 5.1 should be included in the Repair Code.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
RP	352	352.1R	Same as 352R.	26		This is an old document that is replaced by 352R.	Document is for all practical purposes not in existence.
RP	352	352R	Recommendations for Design of Beam-Column Connections in Monolithic Reinforced Concrete Structures	37		Document summarizes the recommendations for detailing and designing joint regions in structural frames to ensure strength and ductility.	Leave document with committee.
FG	355	355.1R-91	State of the Art Report on Anchorage to Concrete (not in MCP)	71	Chapter 1 Introduction, Chapter 2-Types of Anchoring devices, 2.1 Introduction, 2.2 Scope 2.3 Anchor systems, 2.4 Cast in place systems 2.5 Post installed systems, Chapter 3--Behavior of anchors, 3.1 Introduction, 3.2 Behavior of anchors in uncracked concrete, 3.3 Behavior of anchors in cracked concrete, 3.4 Behavior of cast in place anchor bolts in uncracked concrete piers, 3.5 References, Chapter 4--Design considerations, 4.1 Introduction, 4.2 Functional requirements, 4.3 Materials, 4.4 Design basis, 4.5 Construction practices, 4.6 References, Chapter 5--Construction considerations, 5.1 Introduction, 5.2 Shop drawings/submittals, 5.3 Tolerances, 5.4 Installation of anchors, 5.5 Inspection, 5.6 Grouting, 5.7 Field problems, Chapter 6--Requirements in existing codes and specifications, 6.1 Introduction, 6.2 Existing codes and specifications, 6.3 Application and development of codes, 6.4 References, Appendix A--Conversion factors, Appendix B--Notations	Anchors are used both as cast in place and post installed systems. Post installed systems whether mechanical or adhesive are common in repair situations. Section 2.5 deals with post installed systems. Chapter 3 discusses behavior of anchors, which is common to both types of systems, but Section 3.3 deals with behavior of anchors in cracked concrete which would be especially applicable to repair. Anchors by definition are used for attachments between components which is common in repair situations.	Section 2.5 and 3.3 should be in the Repair Code commentary. Chapter 3 should also be included with editing. The entire document would be useful to reference in the code.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
FG	355	ACI 355.2-04	Qualification of Post-Installed Mechanical Anchors in Concrete	31	Chapter 1—Scope, Chapter 2—Definitions and notation, 2.1—Definitions, 2.2—Notation, Chapter 3—Significance and use, Chapter 4—General requirements, 4.1—Testing sequence, 4.2—Test samples, 4.3—Testing by independent testing and evaluation agency and by manufacturer, 4.4—Changes to product, Chapter 5—Requirements for test specimens, installation of anchors, and conduct of tests, 5.1—Concrete for test members, 5.2—Anchor installation, 5.3—Test methods, 5.4—Tests in cracked concrete, 5.5—General requirements for anchor behavior, Chapter 6—Requirements for anchor identification, 6.1—Determination of critical characteristics of anchors, 6.2—Specification of critical characteristics of anchors, 6.3—Verification of conformance to drawings and Specifications, Chapter 7—Reference tests, 7.1—Purpose, 7.2—Reference tension tests for single anchors without spacing and edge effects (Table 4.1, Tests 1 and 2, or Table 4.2, Tests 1,2,3, and 4), 7.3—Required calculations using results of reference tests, Chapter 8—Reliability tests, 8.1—Purpose, 8.2—Reliability tests using redu	The entire document deals with anchorage to hardened concrete. Although not limited to repair situations, it is not associated with fresh concrete placement.	Should be included in Repair Code.
FG	355	ACI 355.X (draft for ballot)	QUALIFICATION OF POST-INSTALLED ADHESIVE ANCHORS IN CONCRETE	96	Subject to change	The entire document deals with anchorage to hardened concrete. Although not limited to repair situations, it is not associated with fresh concrete placement.	Should be included in Repair Code.
PC	357	357R-84	Guide for the Design and Construction of Fixed Concrete Offshore Structures	23	1 - General, 2 - Mat's & durability, 3 - Loads, 4 Design, analysis, 5 - Foundations, 6 - Constr, installation & relocation, 7 - Inspection & Repair, 8 References	Very old and outdated document. Chap 7 completely out of date in methods and technical content. Sect 7.3 Repair of concrete, Sect 7.4 crack repairs	Delete chapter 7 from this doc and make reference to 546 docs.
TN	360	360R-92	Design of Slabs on Grade	57	1 - Intro, 2 - Slab types and design methods, 3 Soil support systems, 4 - Loads, 5 - Plain concrete slabs, 6 - Slabs w/shrinkage and temperature reinforcement, 7 - Shrinkage-compensating concrete slabs., 8 - Post-tensioned slabs on grade, 9 - Reducing effects 10 - References	Document deals with design and detailing of new slabs on grade. May need revision since even title appears obsolete. Only new construction.	Leave document with committee.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
PG	362	362.1R-97	Guide for the Design of Durable Parking Structures	40	1-General; 2-Structural system; 3-Durability of materials; 4-Design issues related to construction practice; 5-Design issues related to maintenance practice; 6-References	Section 1.4 Durability Concerns describes deterioration, corrosion, chlorides, and other aspects of durability and corrosion. This summary section is good but it must be coordinated with ACI 201 and ACI 222. The section does reference other ACI documents. Section 3.5 should refer to ACI 515a and ACI 546 discussion on protection systems. Generally the document does a good job of referencing other documents except for ACI 515 and ACI 546, which are not mentioned anywhere.	During next update (currently 1997), the document should include additional references.
PG	362	362.2R-00	Guide for Structural Maintenance of Parking Structures	15	1-Introduction; 2-Developing a maintenance program; 3-Deterioration problems associated with parking structures; 4-General maintenance considerations; 5-Parking facility structural maintenance tasks and frequencies; 6-References; Appendix A-Snow removal; Appendix B-Deicing procedures; Appendix C- Checklist for structural inspection of parking structures	This document is primarily related to maintenance and ongoing assessment of parking structures. The discussion related to periodic assessment, periodic inspections, evaluation checklists, etc. is good but needs to reference ACI 364.1 and ACI 437R. 546R is mentioned in this documents short overview on repair which is good.	no action
LK	363	363	High Strength Concrete	233	1 - Intro, 2 - Selection of Material 3 - Concrete Mix Proportions 4 - Ordering, Batching, Mixing... 5 - Properties of High-Strength Concrete 6 - Structural Design Considerations 7 - Economic Considerations 8 - Applications 9 - Summary 10 - References	The word repair is given once in the entire document	Do nothing.
PG	363	363.2R-98	Guide to Quality Control and Testing of High-Strength Concrete	18	1-Introduction; 2-Planning; 3-Quality assurance and quality control; 4-Testing; 5-Evaluation of compressive strength test results; 6-References	"repair" only mentioned generally in discussion of use of fly ash in repair materials and in references.	No action
PG	363	363R-97	State of the Art Report on High-Strength Concrete	55	1-Introduction; 2-Selection of materials; 3-Concrete mix proportions; 4-Batching, mixing, transporting, placing, curing, and control procedures; 5-Properties of high-strength concrete; 6-Structural design considerations; 7-Economic considerations; 8-Applications; 9-Summary; 10-References	No mention of concrete "repair"	No action

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
FG	364	ACI 364.1 R-94	Guide for Evaluation of Concrete Structures Prior to Rehabilitation	22	Chapter I-Introduction, I.I-General, 1.2-Definitions, 1.3-Purpose and scope, Chapter 2-preliminary investigation, 2.1-Introduction, 2.2-Scope and methodology, 2.3-Results, Chapter 3-Detailed investigation, 3.1-Introduction, 3.2-Documentation, 3.3-Field inspection and condition survey, 3.4-Sampling and material testing, 3.5-Evaluation, 3.6-Final report, Chapter 4-Documentation, 4.1-Introduction, 4.2-Design information, 4.3-Materials information, 4.4-Construction information, 4.5-Service history, 4.6-Communication, Chapter 5-Field observations and condition survey, 5.1-Introduction, 5.2-Preparation and planning, 5.3-Field verification of as-built construction, 5.4-Condition assessment, 5.5-Unsafe or potentially hazardous conditions, Chapter 6-Sampling and material testing, 6.1-Introduction, 6.2-Determination of testing requirements, 6.3-Testing and evaluation 6.4-Nondestructive evaluation methods, 6.5-Sampling techniques, Chapter 7--Evaluation, 7.1-Introduction, 7.2-Dimensions and geometry, 7.3-Material evaluation, 7.4-Structural evaluation, 7.5-Evaluation of rehabilitation alternatives, 7.6-Co	The entire document deals with Repair and rehabilitation situations	Should be included in Repair Code.
FG	364	FAQ's	Frequently Asked Questions, not in MCP	variable	numerical order of initial discussion	in various stages of development with 10 completed and published. Designed to address "hot topics" of the repair industry not addressed by other documents in ACI.	Use information from published documents as appropriate, possible mechanism is to pose additional questions for needed topics to achieve consensus and TAC review for inclusion in Repair Code.
PC	365	365.1R-00	Service-Life Prediction--State-of-the-Art Report	44	1 - Intro, 2 - Environ design, construct, considerations, 3 - in-service inspection, condition assessment, remaining life, 4 - methods for predicting serv life, 5 - economic considerations, 6 - Examples of serv life techniques, 7 - On-going work and needed development, 8 References	The document deals with service life of concrete, and words 'repair' and 'rehabilitation' appear frequently in the theoretical concept of 'when to repair or replace', but the document does not cover any specific repair methods.	This committee deals with the service life of <u>existing</u> structures. The committee's scope work is foreign to TAC and should be overseen by TRRC.
PE	371					No repair in this document	
PG	372	372R-03	Design and Construction of Circular Wire- and Strand-Wrapped Prestressed Concrete Structures	24	1-General; 2-Design; 3-Materials; 4-Construction procedures; 5-Acceptance criteria for liquid-tightness of tanks; 6-References; Appendix A-Recommendations and considerations related to the design and construction of tank foundations	"repair" is only mentioned with regard to water-tightness of water retaining structures	No action

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
TN	373	373R-97	Design and Construction of Circular Prestressed Concrete Structures with Circumferential Tendons	26	1 - General, 2 - Materials, 3 - Design, 4 - Construction procedures, 5 - Acceptance criteria for liquid-tightness	The document relates to design and construction of new structures. There is no mention of repair.	Leave document as is with committee. Since the committee has knowledge in the area of external post-tensioning, it could be asked to consider the preparation of a repair document for circular structures.
RP	408	408.2R	State-of-the-Art Report on Bond Under Cyclic Loads	32		Document summarizes the effects of cyclic load on bond and development of reinforcement.	Leave document with committee.
RP	408	408.3R	Splice and Development Length of High Relative Rib Area Bars in Tension	6		Summarizes the effect on bond of increasing the rib size of bars.	Leave document with committee.
RP	408	408R	Bond and Development of Straight Bars in Tension	49		Document represents the state of the art on developing reinforcing bars in tension.	Leave document with committee.
JMD	423	423.3R-96	Recommendations for Concrete Members Prestressed with Unbonded Tendons	19	1 - Introduction; 2 - Design Considerations; 3 - Design; 4 - Materials; 5 - Construction; 6 - References	No mention of concrete "repair"	No action
JMD	423	423.4R-98	Corrosion and Repair of Unbonded Single Strand Tendons	20	1 - Introduction; 2 - Review of code requirements and changes; 3 - Unbonded tendons; 4 - Evaluating corrosion damage; 5 - Repair schemes and methods; 6 - Summary; 7 - References	"repair" in this document is primarily related to repair of tendons. Limited discussion of concrete repair includes references to ACI 224 and 546	No action
JMD	423	423.5R-99	State-of-the-Art Report on Partially Prestressed Concrete	37	1 - Introduction; 2 - Partially prestressed members under static loading; 3 - Time-dependent behavior; 4 - Effects of repeated loading (fatigue); 5 - Effects of load reversals; 6 - Applications; 7 - References; Appendix - Notations	"repair" does not appear in this document	No action
JMD	423	423.6-01/423.6R-01	Specification for Unbonded Single-Strand Tendons and Commentary	29	1 - General; 2 - Products; 3 - Execution	"repair" in this document is primarily related to repair of sheathing	No action
TN	437	437R-03	Strength Evaluation of Existing Concrete Buildings	28	1 - Intro, 2 - Preliminary investigation, 3 - Methods for material evaluation, 4 - Assessment of loading conditions, 5 - Evaluation, 6 - References	The document deals with the evaluation of existing concrete structures from properties of material to in-situ load testing.	This document should be within the jurisdiction of TRRC as it pertains to the phase of structural assessment necessary prior to any repair/upgrade.
PC	439	439.3R-91	Mechanical Connections of Reinforcing Bars	16	1 - General, 2 - Design requirements, 3 - Devices and Installation Descriptions, 4 - Summary, 5 - References	No mention of repair or rehabilitation, except 'repair of bar coatings'. The general topic is relevant to 546.	Leave document status as is.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
TN	440	440.1R-03	Guide for the Design and Construction of Concrete Reinforced with FRP Bars	42	1 - Intro, 2 - Background info, 3 - Material characteristics, 4 - Durability, 5 - Material requirements, 6 - Construction practices, 7 - General design, 8 - Flexure, 9 - Shear, 10 - Temp and shrinkage reinforcement, 11 - Development and splices, 12 - Slabs on ground, 13 - References	A new version will be available in 2006 as already approved by TAC. This document only relates to new construction.	Leave document as is with committee. The part of technology related to repair, (near surface mounted reinforcement) will be handled in a separate document, (4402R) when it is revised.
TN	440	440.2R-02	Guide for the Design and Construction of Externally Bonded FRP Systems for Strengthening Concrete Structures	45	1 - General, 2 - Materials, 3 - Recommended constructio requirements, 4 - Design recommendations, 5 - Design examples	The document is aging because the technology moves so fast. A new revision is expected shortly. This document is TOTALLY related to repair and upgrade of concrete structures.	This document should be within TRRC jurisdiction as it relates to existing structures.
TN	440	440.3R-04	Guide Test Methods for Fiber-Reinforced Polymers (FRPs) for Reinforcing or Strengthening Concrete Structures	40	1 - General, 2 - Test methods for FRP bars, 3 - Test methods for FRP laminates, 4 - References	The document reports on test methods for material characterization since such test standards are not yet available in ASTM. ASTM itself is using this document as a strawman.	Leave document with committee.
TN	440	440.4R-04	Prestressing Concrete Structures with FRP Tendons	35	1 - Intro, 2 - FRP tendons and anchorages 3 - Flexural design, 4 - Serviceability, 5 - Shear, 6 Bond and development, 7 - Unbonded and external tendon systems, 8 - Pile driving and in-place flexure, 9 - Research needs, 10 - References	This document is a state-of-the-art type publication on prestressing with FRP. Even Ch. 7 that deals with external post-tensioning is only related to new construction as the rest of the document.	Leave document with committee.
TN	440	440R-96	State-of-the-Art Report on Fiber Reinforced Plastic (FRP) Reinforcement for Concrete Structures	68	1 - Into, 2 - FRP composities, 3 - Mechanical properties and test methods, 4 - Desing guidelines, 5 - Behavior of structural elements 6 - Prestressed concrete elements, 7 - External reinorcement, 8 - Field applications, 9 - Research needs, 10 - References	Committee is balloting a new version of this document given the significant amount of interest and use in this technology. Ch. 7 of this document is completely devoted to strengthening and repair. Ch. 8, Section 3 is devoted to applications in repair.	Since the major interest in the use of FRP is in repair and strengthening, there is a need for a separate SOA report on this topic.
JMD	446	446.1R-91	Fracture Mechanics of Concrete: Concepts, Models and Determination of Material Properties	23	Abstract only		No action
JMD	446	446.3R-97	Finite Element Analysis of Fracture in Concrete Structures: State-of-the Art	33	1 - Introduction; 2 - Discrete crack models; 3 - Smeared crack models; 4 - Literature review of FEM fracture mechanics analyses; 5 - Conclusions; 6 - References; Appendix-Glossary	"repair" appears only once in this document	No action
JMD	446	446.4R-04	Report on Dynamic Fracture of Concretete	29	1 - Introduction; 2 - Experimental evidence of rate effects; 3 - Analytical modeling of strain-rate effects; 4 - Computational modeling of localized failure under dynamic loading; 5 - Summary; 6 - References	"repair" does not appear in this document	No action

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
MS	503	5031-92				specification	No action
MS	503	5032-92				specification	No action
MS	503	5033-92				specification	No action
MS	503	5034-92				specification	No action
MS	503	5035R-92					No action
MS	503	5036R-97			2, 3 and 4	sections discuss surface evaluation, concrete removal and surface preparation	may want to reference documents on surface evaluation, concrete removal and surface preparation
MS	503	503R-93			5	sections discuss surface evaluation, concrete removal and surface preparation	may want to reference documents on surface evaluation, concrete removal and surface preparation
MS	504	504R-90			7.2.1	section discusses header repair	section should reference a document on header repair
PC	506	506.1R-98	Committee Report on Fibre Reinforced Shotcrete"	11	1 - Intro, 2 - steel-fiber reinforced shotcrete, 3 - synthetic fiber reinforced shotcrete, 4 - references	Introduction mentions use in repair of tunnels and mine linings, surface repairs. Section 2.7 'Applications' – repair of deteriorated concrete surfaces, lighthouse and chimney repairs	
PC	506	506.2-95	Specification for Shotcrete	8	1 - General, 2 - Materials, 3 - Execution,	Chapter 3 covers surface prep, finishing, curing, hot weather, cold weather, and other items related to placement.	Leave document status as is.
PC	506	506.3R-91	Guide to Certification of Shotcrete Nozzlemen	13	1 - Intro, 2 - Certification, 3 - Evaluation of exam, 4 - Summary, 5 - references, many appendices on exam questions	This document covers material that is only pertinent to 506 committee	Leave document status as is.
PC	506	506.4R-94	506.4R-94 "Guide for the Evaluation of Shotcrete" (12 pages)	12	1 - Intro, 2 - Strength, 3 - Bond, voids, 4 - Density, 5 - Permeability, 6 - Eval of plastic shotcrete, 7 - Determin of shotcrete, 8 - References	No mention of word 'repair' in this document, but it does include significant discussion of various testing methods for assessment.	Leave document status as is.
PC	506	506R-90	Guide to Shotcrete	41	1 - General, 2 - Materials, 3 - Equipment, 4 - Crew organization, 5 - Preliminary procedures, 6 - Proportioning and preconstruction testing, 7 - Batching & mixing, 8 - Placement, 9 - QC, 10 - References	There are numerous references to repair of concrete throughout the 506 document. There is current overlap with 546 repair guide, shotcrete being covered in both documents.	Shotcrete is both a construction and a repair process, so two documents may be needed. Either a new 506 document exclusively for concrete repair is needed, or 546 repair guide section on shotcrete should be expanded and the 506 document edited.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
JP	515	515R	A Guide to the Use of Protective and Decorative Systems for Concrete			This document has not yet been approved by TAC. This review is based on the most recent draft. Chapter 2 is devoted to surface preparation. ACI 546 is referenced for repair of surface defects in cast-in-place concrete. This document also indicates that structural repairs require engineered repair.	Although this document needs to go through TAC, no changes regarding concrete repair are required in the current draft.
PC	524	524R-04	Guide to Portland Cement Based Plaster	40	1 - Purpose, 2 - Intro, 3 - Desirable properties 4 - Materials, 5 - Bases, 6 - Lathing accessories, 7 - Design considerations, 8 - Install lath, 9 - Surf prep for plaster, 10 - Proportions and mixing, 11 - Application of plaster, 12 - Plaster finishes, 13 - Eval of Plaster, 14 - Testing, 15 - Patching & repair, 16 - Tools, 17 - References	Entire document is related to plaster, rather than concrete. No conflicts with 546. Chapter 14 covers repair of cracks, delamination, debonding, chemical attack, freeze-thaw	Leave document status as is.
LK	530	ACI 530.1-05/ASCE 6-05/TMS 602-05	Specification for Masonry Structures (and Commentary)	26 (17)	1- general; 2- products; 3- execution	Repair is not mentioned in the Specification or its Commentary	Do nothing.
LK	530	ACI 530-05/ASCE 5-05/TMS 402-05	Building Code Requirements for Masonry Structures (and Commentary)	73 (85)	1- general requirements; 2- allowable stress design; 3- strength design; 4- prestressed; 5- empirical design; 6- veneer; 7- glass unit; Appendix A- Autoclaved Aerated Concrete	Repair is not mentioned in the Code or its Commentary	Do nothing.
PE	533				Chapter 6-Installation, pg. 533R- 6.1-Planning and preparation 6.2-Unloading and handling 6.3-Jobsite storage 6.4-Installation 6.5-Cleaning 6.6-Patching and repair- covered in our core documents 6.7-Joint sealing (caulking)		

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
FG	543	ACI 543R-00	Design, Manufacture, and Installation of Concrete Piles	49	Chapter 1—Introduction, 1.0—General, 1.1—Types of piles, Chapter 2—Design, 2.0—Notation, 2.1—General design considerations, 2.2—Loads and stresses to be resisted, 2.3—Structural strength design and allowable service capacities 2.4—Installation and service conditions affecting design, 2.5—Other design and specification considerations, Chapter 3—Materials, 3.1—Concrete, 3.2—Reinforcement and prestressing materials, 3.3—Steel casing, 3.4—Structural steel cores and stubs, 3.5—Grout, 3.6—Anchorages, 3.7—Splices, Chapter 4—Manufacture of precast concrete piles, 4.1—General, 4.2—Forms, 4.3—Placement of steel reinforcement, 4.4—Embedded items, 4.5—Mixing, transporting, placing, and curing concrete, 4.6—Pile manufacturing, 4.7—Handling and storage, Chapter 5—Installation of driven piles, 5.0—Purpose and scope, 5.1—Installation equipment, techniques, and methods, 5.2—Prevention of damage to piling during installation, 5.3—Handling and positioning during installation, 5.4—Reinforcing steel and steel core placement, 5.5—Concrete placement for CIP and CIS piles, 5.6—Pile det	Repair is briefly mentioned, but no specifics regarding techniques or even references for further information. Damage is mentioned frequently, but usually as preventative measures. Some brief discussion about pile inspection is included, but nothing especially useful for repair.	Develop separate document. Likely will be from scratch if needed.
TN	544	544.1R-96	State-of -the-Art Report on Fiber Reinforced Concrete	66	1 - Intro, 2 - Steel fiber reinforced, 3 - Glass fiber reinforced, 4 - Synthetic fiber reinforced, 5 - Natural fiber reinforced	Revision of a document originally published in 1982. Very outdated. For each chapter dedicated to a fiber type, there could be a section on repair applications that has become of interest in recent years.	Leave document status as is. Ask committee to consider complete update and potentially include repair
TN	544	544.2R-89	Measurement of Properties of Fiber Reinforced Concrete	11	1 - Intro, 2 - workability, 3 - Air content, yield and unit weight, 4 - Specimen preparation, 5 - Compressive strength, 6 - Flexural strength	Outdated document. New practices and test methods have been instituted by groups such as ASTM and RILEM. No reference to repairs.	Leave document in committee jurisdiction. Suggest its update.
TN	544	544.3R-93	Guide for Specifying, Proportioning, Mixing, Placing, and Finishing Steel Fiber Reinforced Concrete	10	1 - General, 2 - Materials, 3 - Mixture proportioning, 4 - Formwork and reinforcing steel, 5 - Batching, mixing, delivery, & sampling, 6 - Placing and finishing, 7 - Curing and protection, 8 - References	As all other 544 documents, very outdated. There is mention of practices that are relevant to TRRC such as; a) bridge deck overlays, b) shotcrete coverings.	Leave document in committee discussion. Request committee to consider writing a document for repair applications. There should be also a separate chapter on repair for FRC itself.
TN	544	544.4R-88	Design Consideration for Steel Fiber Reinforced Concrete	18	1 - Intro, 2 - Mechanical properties used, 3 - Design applications, 4 - References	Dated document. No repair covered.	Leave document status as is.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
PG	546	546.2R-98	Guide for Underwater Repair of Concrete	24	1-General; 2-Causes of deterioration; 3-Evaluations and investigations; 4-Preparation for repair; 5-Formwork; 6-Methods and materials; 7-Inspection of repairs; 8-Developing technologies; 9-References	This document does a good job of describing topics through reference in combination with differences associated with underwater repair work. References to ACI 546R and ICRI to be added.	No action
PG	546	546R-04	Concrete Repair Guide	53	1-Introduction; 2-Concrete removal, preparation and repair techniques; 3-Repair materials; 4-Protective systems; 5-Strengthening techniques; 6-References	This is of course one of the base repair documents. Once the ACI 546 Material Selection Guide a portion of this document should be revised to account for the detail of this new material selection information and refer to this documents for more detail. Chapter 4 Protective Systems should be revised and refer to ACI 515 for more detail once this document has been updated.	No action
KP	547					No documents in MCP	No action
MS	548	5481R-97			4.3.6 and 4.5.4	discusses patching	may want to reference documents on concrete removal and surface preparation
MS	548	5481R-97			4.5	discusses construction procedures	may want to update references to other documents on construction procedures for PMC
MS	548	5482R-93			2.3 and 2.4	sections discuss surface evaluation, concrete removal and surface preparation	may want to reference documents on surface evaluation, concrete removal and surface preparation
MS	548	5483R-03			2.5 and 4.8	sections discuss surface preparation and placing and curing concrete	may want to update references on surface preparation, placement and curing
MS	548	5484-93				specification	No action
MS	548	5485R-94			4	deals with surface preparation, patching and crack repair	may want to refer to documents on surface preparation, patching and crack repair
MS	548	5487-04					No action
TN	549	549.1R-93	State-of-the-Art Report on Ferrocement	26	1 - Intro, 2 - History, 3 - Composition and construction, 4 - Physical and mechanical properties, 5 - Performance criteria, 6 - Applications of ferrocement, 7 - Research needs, 8 - References	This document is a revised version of the original 1993 version. It does not cover repair but only new construction.	Leave document status as is.

Member	Current Committee #	Current Doc #	Document Name	Size (pages)	Chapter Names	Comments	Recommendations
RP	550	550.1R	Emulating Cast-in-place Detailing in Precast Concrete Structures	16		Document summarizes the detailing requirements to achieve monolithic type behavior with precast concrete elements.	Leave document with committee.
RP	550	550R	Design Recommendation for Precast Concrete	8		Document summarizes the recommendation for design of precast members.	Leave document with committee.
MS	551	5511R-05			8.1 and 8.2	sections discuss surface preparation, patching and crack repair	sections should reference documents on surface preparation, patching and crack repair
MS	551	551R-92			6.8.3	section discusses crack repair	section should reference a document on crack repair