



Cont.
from
Page 1



Problem – See Sect. 1.1.6 – the design basis codes (IEBC etc.) do not address deficiencies resulting from faulty design or construction



We could amend Sect. 1.1.6 to include restoration of existing members and system to original building code provisions with a limit not to exceed current code provisions

